

## Product Specification: UltraTEV<sup>®</sup> Plus<sup>2</sup> Wireless Phase Reference (UTP2-WPR)





Make Partial Discharge discovery simple

www.eatechnology.com/sea

CHANGE HISTORY			
DATE	VERSION	AUTHOR	CHANGES
25/04/23	1		

## UltraTEV<sup>®</sup> Plus<sup>2</sup> Wireless Phase Reference (UTP2-WPR)

Physical	
Size	115*118*50mm
Weight	5200g
Enclosure	Injection moulded plastic case
Connectors	1x GCS1 Current Sensor (for a cable of 1.5m in length) 1x Power Barrel connector
Mounting Mechanisms	Freestanding Magnets in feet to attach to any magnetic surface. Velcro Strap to wrap around cables (up to 100mm diameter)

Environmental	
Operating Temperature	-20 - +50 degrees °C
Humidity	0 – 95% non-condensing
IP Rating	42 (BS EN 60529)
Impact Rating	1IK08 (BS EN 62262)

Indicators and Controls	
Indicators	4x LEDs to indicate current Phase Reference Source 1x bicolour LED for Wi-Fi/WPS status 1x LED to indicate charging status 3x LEDs for the Battery Level
Controls	3x Push Buttons

Power Supplies	
Internal batteries	Lithium Polymer 3.7V, 2000mAh
Operating Time	Approx. 16 hours
Battery Conservation	Automatic shutdown after 15 minutes of not being connected.
Power input	9Vac 50Hz/60Hz, 5W
Charging Time	Approx. 3h

Battery Charger/AC power port	
Rated voltage	230 VAC
Frequency	50Hz
Max output current	1.1 A
Output Voltage	9VAC
Power Rated	15W
Environment	-10 To 40 degrees C, 0-90%RH
Cable Length	Input: 2.0m Output: 1.8m

Con	nectivity
0011	lectivity

Wireless

Wi-Fi (IEEE 802.11) – Connecting to the UTP2

Frequency: 2.4 GHz Maximum Power: +19.97 dBm Model Number: ESP32-C3-WROOM-02 Antenna: PCB Antenna, 3.42dBi Certificate Number: E1177-210909 Certificate Issued by: Notified Body 1177, TIMCO Engineering, Inc.

Phase Reference	
Sources	Mains Input Power, Lighting (Photo sensor), Electric field (High-Z sensor), Rogowski Coil
Frequency Range	50 Hz ± 1%, 60 Hz ± 1%
Accuracy	±5deg

Compliance	
	BS EN IEC 61326-1:2021 (Electrical equipment for measurement, control, and lab
	use – EMC requirements)
Electromagnetic	BS EN 61000-3-2: 2019 Electromagnetic compatibility (EMC) Part 3-2: Limits
compatibility (EMC)	<ul> <li>Limits for harmonic current emission</li> </ul>
	BS EN 61000-3-3: 2013 + A1: 2019 (Limitation of voltage changes, voltage fluctua-
	tions and flicker in public low-voltage supply Systems)
Radio	ETSI EN 301 489-17 V3.2.4 (EMC standard for radio
	equipment and services, for Broadband Data Transmission
	Systems)
	ETSI EN 301 489-1 V2.2.3 (EMC standard for radio equipment
	and services; Part 1: Common technical requirements)
Safety	BS EN 61010-1:2010+A1:2019 (Safety requirements for electrical equipment for
	measurement, control, and laboratory use)

For more information please call us on +65 6443 3833 or email us at sales@eatechnology.sg

## **Global Footprint**

At EA Technology we specialise in asset management solutions for owners and operators of power network assets.



Founded in 1966 we have over 50 years' experience in the industry and 6 regional offices around the world to support our global customer base. We help clients to safeguard their networks. Advising them on strategy and implementation of a range of technology solutions to manage power assets, delivering maximum life and minimising cost



## Safer, Stronger, Smarter Networks

**EA Technology Singapore** EA Technology Asset Management Pte Ltd 4 Kaki Bukit Avenue 1 #01-02 Singapore 417939 t +65 6443 3833 e sales@eatechnology.sg www.eatechnology.com/sea