



Addressing Noise Sources During Online PD Testing

Timothy Erwin

National Sales Manager, EA Technology LLC

March 11, 2019



Agenda

- Review: What is PD?
- Example 1: Noise (?)
- Example 2: Power inverters and different technologies
- Example 3: Dry-type transformers
- What can we do to avoid these problems?
- What did we learn?



EA Technology Group

- Originally established as R&D Center for the UK Electricity Industry. Privatized in the early 1990s.
- Provides research, strategic engineering consultancy, HV asset condition assessment services, specialized instrumentation and asset management software and consulting.
- Discovered the TEV effect in 1978 and developed the first practical detection method in 1982
- Instrumental in the development of PAS-55 and ISO-55000
- Maintains a large forensic investigation lab equipped with the latest technology and staffed by highly experienced scientists.

POWERTEST[®]

CONFERENCE


Is Partial Discharge Real?



What is Partial Discharge?


PD failure process

- Multiple causes
- Starts small
- ALWAYS gets worse
- Leads to FLASHOVER




PD is the inability of a portion of the insulation to withstand the electric field applied to it

Partial Discharge - A flashover of part of the insulation system due to a localized electric field greater than the dielectric withstand capability of that part where the overall insulation system remains capable of withstanding the applied electrical field.




One effect of this flashover is a high frequency current pulse that travels through the capacitance of the insulation (C1 & C3)

Phase Resolved Plots



Partial Discharge tends to occur on the rising edge of the voltage sine wave. As such, PD impulses tend to be synchronized to the AC waveform and 180 degrees apart.

Phase Resolved plots show PD impulses on a power system cycle so groupings 180 degrees apart can be seen.





Online test classifications

- **Ultrasonic/Acoustic** testing – through louvers, vents, contact sensors, and parabolic dishes (Audio over 20KHz)
- **TEV testing** – Makes use of the Transient Earth Voltage phenomenon to safely detect internal discharge from outside cabinets
- **RFCT testing*** - By attaching RFCT to cable ground straps, the PD current can be safely measured on live cables
- **RF Testing** – Specifically designed directional and non-directional radio receivers can pickup the EMI generated by PD

* installing RFCT on live cables requires opening the HV compartment and appropriate safety measures





Types of PD


- **Internal discharges** occurring in defects, voids or cavities within solid insulation (TEV, UHF, RFCT, IR)
- **Surface discharges** occurring across the insulation surface (Ultrasonic, UHF, RFCT)
- **Corona discharge** occurring in gaseous dielectrics in the presence of inhomogeneous fields (Corona Camera, Ultrasonic, UHF,)
- **Contact discharge** occurs on floating metal in high field conditions (TEV, Ultrasonic, UHF)

Surface PD – Flexible microphone




- 11kV HV Cable phases too close to insulated plastic boot
- Can be just heard with naked ear



Metadata	
Panel Number:	2
Asset Name:	
Component:	Cables
Sub Location:	Red 1
Insulation:	XLPE
Switch Position:	Closed
Comments:	White discharge seen on red heatshrink at base of white cover
Measurement	
Measurement (dBμV):	24
Ultrasonic Accessory:	Flexible Microphone
Ultrasonic Classification:	PD
Classification Certainty (%):	94
Phase Reference Locked:	True
Graph Control	
	




Surface PD, Crossed phases – Contact Probe



- 11kV HV Cable phases too close – crossed phases
- Can see 180 degree clustering
- Difficult to determine from single reading but obvious on site as only difference in switchboard

Metadata	
Panel Number:	4
Asset Name:	
Component:	Lower Busbars
Sub Location:	
Insulation:	
Switch Position:	Closed
Comments:	Back panel bus section
Measurement	
Measurement (dB _{uV}):	1
Ultrasonic Accessory:	Contact Probe
Ultrasonic Classification:	PD
Classification Certainty (%):	76
Phase Reference Locked:	True
Phase Reference Source:	Photo
Graph Control	
 	




Corona / Surface PD – Flexible Microphone



- 11kV connection at rear of CB spouts, poor insulation interface
- Note white build up, also rust and green verdigris
- Corona with some surface PD – can be seen in phase resolved pattern
- Corona tends to have a 'deeper' sound

Metadata	
Panel Number:	1
Asset Name:	...
Component:	Cable Box
Sub Location:	Centre Left
Insulation:	Air
Switch Position:	
Comments:	
Measurement	
Measurement (dB μ V):	16
Ultrasonic Accessory:	Flexible Microphone
Ultrasonic Classification:	PD
Classification Certainty (%):	97
Phase Reference Locked:	True
Graph Control	




Corona, 132kV Isolator - Ultrasonic



- 132kV isolator, sharp point into air
- High ultrasonic
- Note one peak of activity on one half of sine wave

Metadata	
Panel Number:	2
Asset Name:	132kV Tx Isol
Component:	Upper Busbars
Sub Location:	
Insulation:	
Switch Position:	Closed
Comments:	White ph on Tx side corona
Measurement	
Measurement (dB μ V):	36
Ultrasonic Accessory:	UltraDish
Ultrasonic Classification:	PD
Classification Certainty (%):	64
Phase Reference Locked:	True
Phase Reference Source:	E Field




Magnetic Transformer Vibration, Contact Probe



- 11kV Transformer magnetic vibration noise detected with contact probe – no problem detected
- Sound goes away when metal plate is physically leant on – stops vibrating
- Note 4 clusters of activity in phase resolved plot, not indicative of PD


Metadata	
Panel Number:	1
Asset Name:	Tx
Component:	Cable Box
Sub Location:	Centre Right
Insulation:	Air
Switch Position:	
Comments:	Possible vibration, goes away when touching metal with hand
Measurement	
Measurement (dBV):	2
Ultrasonic Accessory:	Contact Probe
Ultrasonic Classification:	PD
Classification Certainty (%):	74
Phase Reference Locked:	True
Phase Reference Source:	Manual
Graph Control	



POWERTEST[®]

CONFERENCE

Noise, Industrial- TEV



- Industrial noise from factory load - 212.41 PPC count
- No PD signals can be detected





Example 1: NOISE(?)

POWERTEST[®]

CONFERENCE




Ultrasonic - 2-7

UltraTEV²
Plus²

Audio Files NFC Phase Resolved

Metadata	
Panel Number:	9
Asset Name:	2-7
Component:	Circuit Breaker
Sub Location:	
Insulation:	
Switch Position:	Closed
Comments:	
Measurement	
Measurement (dBμV):	18
Ultrasonic Accessory:	Flexible Microphone
Ultrasonic Classification:	PD
Classification Certainty (%):	64
Phase Reference Locked:	True
Phase Reference Source:	Manual
Graph Control	



- “Typical” switchgear
- Breakers, busbars
- No motors or rotating equipment
- PD Indication
- Low certainty
- No Phase Resolve Plot
- Let’s take a listen...



- That is something
- Not really electrical but close
- Sounds a little more mechanical

POWERTEST[®]


CONFERENCE



Ultrasonic - 2-8

UltraTEV[®]
Plus²

Metadata	
Panel Number:	10
Asset Name:	2-8
Component:	Circuit Breaker
Sub Location:	
Insulation:	
Switch Position:	Closed
Comments:	
Measurement	
Measurement (dB μ V):	18
Ultrasonic Accessory:	Flexible Microphone
Ultrasonic Classification:	Noise
Classification Certainty (%)	79
Phase Reference Locked:	True
Phase Reference Source:	Manual
Graph Control	



Neighboring cell:

- Similar levels and pattern
- Classified as **noise**
- Fairly high % certainty



Very similar sound

POWERTEST[®]


CONFERENCE



Ultrasonic - 2-6



Metadata	
Panel Number:	8
Asset Name:	2-6
Component:	Circuit Breaker
Sub Location:	
Insulation:	
Switch Position:	Closed
Comments:	
Measurement	
Measurement (dBuV):	10
Ultrasonic Accessory:	Flexible Microphone
Ultrasonic Classification:	Noise
Classification Certainty (%):	69
Phase Reference Locked:	True
Phase Reference Source:	Manual
Graph Control	




- Located midway on 9 section lineup
- Classified as Noise
- Levels similar. (All sections)
- Rotated microphone, levels stayed consistent



Ultrasonic - 2-9



Metadata	
Panel Number:	11
Asset Name:	2-9
Component:	Circuit Breaker
Sub Location:	
Insulation:	
Switch Position:	Closed
Comments:	
Measurement	
Measurement (dBuV):	13
Ultrasonic Accessory:	Flexible Microphone
Ultrasonic Classification:	PD
Classification Certainty (%):	51
Phase Reference Locked:	True
Phase Reference Source:	Manual



- End section of gear
- Near large floor circulating fan



- Audio is high pitched, well above 120 Hz
- Not like sections 7 and 8.
- Most likely from fan, possibly bearing noise

POWERTEST[®]

CONFERENCE

- High levels of background noise most likely caused by circulation fans and AC units within an isle's width of the gear.
- Because of mid summer temps we were unable to turnoff auxiliary fans.
- There is something at sections 7 and 8. Not necessarily PD, possibly loose metal or panel vibrating.
- Our work permit did not allow opening of energized equipment. Investigation is ongoing.
- UHF detector @ 800 MHz probably would have eliminated a lot of background noise giving better indication of PD



Example 2: Power inverters and different detection technologies



Electronic switching inverters

Locations with switching inverters are problematic as they tend to be very noisy in the spectrums where we look for PD.

Common in windfarms, solar farms and scientific manufacturing facilities that need very clean power


These locations also tend to be tight on space and utilize dry type transformers that also radiate their own noise signatures.

Operate in the range of 10's to 100's KHz

POWERTEST[®]

CONFERENCE

Example 1: Scientific manufacturing facility in room with switching inverters




Ultrasonic

- Background levels in room high
- Significant noise level
- Gain could be masking lower level PD

POWERTEST[®]

CONFERENCE

Example 1: Scientific manufacturing facility in room with switching inverters



TEV:

- High levels 43 Db
- High Pulse Per Cycle count - 50.79
- Within background levels of 39Db and 41.15 PPC

POWERTEST[®]

CONFERENCE

Example 2: Wind Turbine with known PD in basement mounted transformer




- Transformer had been tested with off-line equipment and it was determined that there was PD on at least one winding
- Testing with multiple online technologies was performed including
 - TEV
 - Ultrasonic
 - RFCT on transformer incoming, tail and chassis ground straps
 - Radiometric (RF) PD Detector
- Different test equipment was used for the TEV and Ultrasonic, RFCT on cable straps and the RF PD detector.
- Tests were run with the turbines generating and with them off and transformer back fed from the 33Kv side. This allowed a comparison of the affect of the inverters when generating.

POWERTEST[®]

CONFERENCE



TEV: Sample Average amplitude and PPC over 24 hours



- When turbine is on amplitudes are high
- When turbine is off (windspeed dropped) amplitudes drop. From 20-42 dBmV to 0-16 dBmV.
- Alarm threshold is 29 dBmV
- Full time monitoring or planned interruption of turbine operation would be necessary.


Measurements are recorded on 3 types of probes- internal and external types and an antennae at multiple locations near each winding

TEV: Phase resolved plot- Probe on transformer panel.




- Measurements with inverters operating will not allow TEV detection
- But with inverters stopped the PRP shows PD.

TEV: Phase resolved plot- Probe on transformer panel.



Clear PD pattern with turbine stopped, inverts off.

Ultrasonic: Average amplitude over same 24 hours as TEV



- Similar trend as TEV
- Low levels of U.S. activity when inverter was off suggest it is not possible to use U.S. as a method of PD detection in transformers

Because the transformers have solid resin insulation there is no airpath out, so ultrasonic internal PD detection is not possible with airborne sensors.

Cable testing- RFCT



RFCT


Incoming 33 kv
interconnect cables

Transformer Tails

POWERTEST[®]

CONFERENCE

Incoming cable winding #1 – Turbine off




- Inverter noise
- No PD Pulse

POWERTEST[®]

CONFERENCE

Incoming cable winding #3- Turbine off




- Inverter noise
- Good PD cluster
- PD Pulse (6K pC)
- Reflected Pulse @ 12.7 ms

POWERTEST[®]

CONFERENCE

Transformer tail winding #3- Turbine off


- No inverter noise
- Good PD cluster
- PD Pulse (9K pC)
- Reflected Pulse @ 12.7 ms



POWERTEST[®]

CONFERENCE

Transformer tail winding #3- Turbine generating




Note levels of noise introduced by the turbine generating.

- No sign of grouping or clustering
- Waveforms characterized by bursts around the trigger point and significant noise on the rest of the waveform
- Filtering does not help significantly.

POWERTEST[®]

CONFERENCE

UHF (RF) Test – Turbine generating



Gain


Center Freq

- Center Freq 777 MHz
- Inverter operating freq. usually 10's to 100's kHz
- Not effected by inverter noise

POWERTEST[®]

CONFERENCE

- UHF (RF) Test – Turbine not generating




- Little difference between turbines on and off
- Little apparent interference from inverters
- PRP was slightly unstable and not exactly 180°
- This may have been caused by inception voltage different on positive and negative half cycles



When the HV transformer was de-energized the pulses stopped and the audio output went quiet.

Sensor placement



Whip antennae


US Microphone

Plate antennae

Telescopic antennae

POWERTEST[®]

CONFERENCE





Dry type transformers


Challenges:

- Vibrate at 2x system frequency (120Hz)- noisy
- Lack of dampening cause vibrations throughout transformer panels etc.
- Significant source of ultrasonic noise.
- Resin cast windings often dampen PD Ultrasonic emissions to the point its undetectable

POWERTEST[®]

CONFERENCE

Ultrasonic Test




- High background noise
- Cannot hear anything on audio
- Cant really make a valid assessment


POWERTEST[®]

CONFERENCE

TEV



- Clusters at 90 deg.
- Not synchronous to 60 Hz (0-PPC)





What have we learned?

- Know the equipment to be tested and understand the environmental impact.
- The use of different technologies, TEV, US, UHF, can provide different results, or supporting data for your conclusions
- Background measurements are valuable for determining if a measurement is real or noise.



Please Remember to Complete
Your Evaluation Form
Thank You!